



**BUREAU  
VERITAS**

CERTIFICATE OF INSPECTION NO.:TPI04018-3

Issuing Center : Taipei, Taiwan  
Supplier/Address : MARS VALVE  
COMPANY LTD.  
7F-6, No.200, Sec. 4,  
Wen-Shin Rd., Taiwan,  
R.O.C

The undersigned, C. H. Su acting with the scope of the General Condition of the Industrial Branch of Bureau Veritas, certifies that the supplies

Type Designation : SERIES 91D-1F FIRE SAFE  
Type of valve : 1- PCs BALL VALVE  
Pressure rating : Class #150  
Nominal size : 1 inch x 1 piece, 2 inch x 1 piece & 4 inch x 1 piece  
Material  
(a) Body : WCB  
(b) Bonnet : WCB  
(c) Seat : PTFE

Inspected at Lung-tan, Taiwan On 22/12/2004, 31/05/2005, 06/07/2005  
& 19/10/2005

has been upon request of : MARS VALVE COMPANY LTD.

Intended for : MARS VALVE COMPANY LTD.

Inspected in conformity with the applicable requirements of the valve fire test per API standard 607 4<sup>th</sup> edition 1993 and contractual requirements governing the mission entrusted to Bureau Veritas.

made at Taipei, Taiwan on 21/12/2005

Signature C. H. Su

Surveyor to Bureau Veritas



Addition qualification of other valves, covered by the valves tests according API standard 607 4<sup>th</sup> editions 1993.

The qualification of ANSI Class : 150, 300

The qualification of Sizes : 3/4", 1", 1 1/4", 1 1/2", 2", 2 1/2", 3", 4", 5" & 6"

Manufacture : MARS VALVE COMPANY LTD.

Particular mentions : The test result of valve fire test is passed.  
Test report of valve fire test attached